
AABC Commissioning Group

AIA Provider Number 50111116



Energy Modeling as a Tool for Retrocommissioning

Course Number: CXENERGY1714

John Bixler, P.E.

NV5 - Sebesta

April 26, 2017



Credit(s) earned on completion of this course will be reported to **AIA CES** for AIA members. Certificates of Completion for both AIA members and non-AIA members are available upon request.

CES for continuing professional education. As such, it does not include content that may be deemed or construed to be an approval or endorsement by the AIA of any material of construction or any method or manner of handling, using, distributing, or dealing in any material or product.

Questions related to specific materials, methods, and services will be addressed at the conclusion of this presentation.

This course is registered with **AIA**



Copyright Materials

This presentation is protected by US and International Copyright laws.
Reproduction, distribution, display and use of the presentation without written
permission of the speaker is prohibited.

N V 5

Course Description


Energy modeling and retrocommissioning (RCx) can effectively share information to aid in building investigations. The session provides an overview of the mechanics of energy modeling, specific energy model inputs that can be enhanced by RCx information, examples of how to include RCx findings in energy models, and discussion of the insights gained from an energy model that should be used in RCx, strategies to capitalize on synergies between the services.

Learning Objectives

At the end of the this course, participants will be able to:

1. Understanding of an energy model.
2. Understand how an energy model can be utilized for existing building analysis.
3. Identify the increased value that can be captured by combining energy modeling and retrocommissioning.
4. Understand how to interpret model outputs in the context of known performance.


DEFINITIONS



Retro-Commissioning:

- ASHRAE: The Cx process applied to an existing facility that was not previously commissioned
- AABC (ACG): Purpose of RCx could be to diagnose the cause of ongoing, unresolved problems, or done as part of a maintenance program

DEFINITIONS



Retro-Commissioning:


Today's definition: Performance analysis of a building that has existed long enough to have useful energy use data



Retro-Commissioning:


- Existing drawing review
- Operator interviews
- Data loggers
- BAS system investigation
- Functional testing
- Trend data analysis
- Utility bill review

DEFINITIONS



Energy Modeling:

DoE definition: Physics-based software simulation of building energy use



AIA take on Energy Modeling:

“The energy model and focus on energy performance is not meant to supplant the importance of design. Rather, a building energy model is a tool that can be utilized throughout the design process to test various design options and optimize the performance of all building typologies.”

One key message of the guide is that architects needn't become technical experts on energy modeling or the myriad software tools currently available. However, a working understanding of the energy modeling process is needed to empower us to fold this necessary and valuable capability into our fundamentally integrative work”



Inputs

Inputs



Inputs


Inputs

Inputs

**Mathematical
Engine**

Outputs





Weather data – including
temp, humidity, wind for
up to 8760 data
points/year

Occupancy schedules
Lighting schedules
Occupant density
Occupant activity

Inputs

Inputs

Inputs

Inputs

Inputs

**Mathematical
Engine**

Outputs

Building dimensions
wall construction
Roof construction
Insulation values
Adjacent shading
Overhangs
Window performance
Thermal mass

Efficiency
Sequencing
Auxillary equipment
Pump characteristics

System design
Zoning
Fan characteristics
System losses
System schedules
OA requirements

Inputs



**Mathematical
Engine**

Outputs

Inputs



**Mathematical
Engine**



Inputs

Inputs

Inputs

Inputs

Inputs

**Mathematical
Engine**


Outputs

Utility use

Room load information
Zone/System load information

Building parameters

Equipment capacity info



Load Information

AHU 1

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK					CLG SPACE PEAK		HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 6 / 15					Mo/Hr: 6 / 17		Mo/Hr: Heating Design						
Outside Air: OADB/WB/HR: 88 / 84 / 173					OADB: 86		OADB: -15						
	Space	Plenum	Net	Percent	Space	Percent	Space Peak	Coil Peak	Percent		Cooling	Heating	
	Sens. + Lat.	Sens. + Lat	Total	Of Total	Sensible	Of Total	Space Sens	Tot Sens	Of Total				
	Btu/h	Btu/h	Btu/h	(%)	Btu/h	(%)	Btu/h	Btu/h	(%)				
Envelope Loads							Envelope Loads						
Skylite Solar	0	0	0	0	0	0	Skylite Solar	0	0	0.00	SADB	55.9	89.0
Skylite Cond	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Ra Plenum	68.0	63.9
Roof Cond	0	14,280	14,280	0	0	0	Roof Cond	0	-33,253	1.26	Return	68.3	63.9
Glass Solar	334,637	0	334,637	11	358,771	30	Glass Solar	0	0	0.00	Ret/OA	70.3	48.4
Glass/Door Cond	92,584	0	92,584	3	91,166	8	Glass/Door Cond	-561,872	-561,872	21.22	Fn MtrTD	0.1	0.0
Wall Cond	37,730	36,980	74,709	2	51,216	4	Wall Cond	-225,941	-393,289	14.85	Fn BldTD	0.3	0.0
Partition/Door	-2,161		-2,161	0	-2,092	0	Partition/Door	-22,208	-22,208	0.84	Fn Frict	0.9	0.0
Floor	0		0	0	0	0	Floor	0	0	0.00			
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0	0			
Infiltration	519,203		519,203	17	84,280	7	Infiltration	-501,453	-501,453	18.94			
Sub Total ==>	981,992	51,259	1,033,252	34	583,341	48	Sub Total ==>	-1,311,475	-1,512,076	57.11			
Internal Loads							Internal Loads				AIRFLOWS		
Lights	235,502	58,876	294,378	10	235,502	20	Lights	0	0	0.00	Diffuser	68,484	64,594
People	231,500	0	231,500	8	115,750	10	People	0	0	0.00	Terminal	76,094	71,771
Misc	202,391	0	202,391	7	202,391	17	Misc	0	0	0.00	Main Fan	84,549	80,226
Sub Total ==>	669,393	58,876	728,269	24	553,643	46	Sub Total ==>	0	0	0.00	Sec Fan	0	0
Ceiling Load	-62,771	62,771	0	0	-60,874	-5	Ceiling Load	-64,634	0	0.00	Nom Vent	6,945	6,945
Ventilation Load	0	0	803,281	27	0	0	Ventilation Load	0	-777,121	29.35	AHU Vent	8,574	8,574
Adj Air Trans Heat	0		0	0	0	0	Adj Air Trans Heat	0	0	0	Infil	5,533	5,533
Dehumid. Ov Sizing			0	0	0	0	Ov/Undr Sizing	-189,432	-189,432	7.15	MinStop/Rh	64,594	64,594
Ov/Undr Sizing	148,438		148,438	5	127,519	11	Exhaust Heat		177,988	-6.72	Return	89,538	85,216
Exhaust Heat		160,107	160,107	5			OA Preheat Diff.		0	0.00	Exhaust	13,563	13,564
Sup. Fan Heat		124,752	124,752	4			RA Preheat Diff.		-346,950	13.10	Rm Exh	543	543
Ret. Fan Heat		26,439	26,439	1			Additional Reheat		0	0.00	Auxiliary	0	0
Duct Heat Pkup		-275,863	0	0			Underflr Sup Ht Pkup		0	0.00	Leakage Dwn	7,609	7,177
Underflr Sup Ht Pkup			0	0			Supply Air Leakage		0	0.00	Leakage Ups	8,455	8,455
Supply Air Leakage		0	0	0									
Grand Total ==>	1,737,052	83,589	3,024,537	100.00	1,203,630	100.00	Grand Total ==>	-1,565,540	-2,647,590	100.00	ENGINEERING CKS		
											Cooling	Heating	
											% OA	10.1	10.8
											cfm/ft²	1.70	1.61
											cfm/ton	335.45	
											ft³/ton	196.81	
											Btu/hr-ft²	60.97	-67.51
											No. People	463	

COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION				
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR		Leave DB/WB/HR			Gross Total		Glass	Capacity		Coil Airflow	Ent	Lvg			
ton	MBh	MBh	°F	°F	°F	°F	gr/lb	°F	°F	ft² (%)	MBh	MBh	cfm	°F	°F			
Main Clg	252.0	3,024.5	1,727.8	84,207	70.3	60.3	63.8	51.6	46.9	41.4								
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0								
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0								
Total	252.0	3,024.5																

Floor	49,606																	
Part	1,435																	
Int Door	0																	
ExFlr	0																	
Roof	6,400	0	0															
Wall	19,492	6,563	34															
Ext Door	0	0	0															

Main Htg	-2,726.0	64,594	51.6	90.2				
Aux Htg	0.0	0	0.0	0.0				
Preheat	-623.1	8,574	-15.0	51.6				
Humidif	0.0	0	0.0	0.0				
Opt Vent	0.0	0	0.0	0.0				
Total	-3,349.1							

Load Information

Add load profiles pictures

Outputs

TOWER ANALYSIS

By Sebesta Inc.

Alternative: 1

Plant / Tower Description	--- Maximum ---				--- Leaving Water Temperature Hours at each Temperature Range (°F) ---													Hours Off	--- Minimum ---			
	Temp	Mo	Hr	Day	>100°	100-95	95-90	90-85	85-80	80-75	75-70	70-65	65-60	60-55	55-50	< 50°	Temp		Mo	Hr	Day	
Air-cooled chiller - 04																						
90.1 Min AirCooled Condenser		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	8,760	0	0	0	0	
Water-cooled chiller - 02																						
Cooling tower for Cent. Chillers		82	7	15	1	0	0	0	0	80	282	509	242	152	0	0	0	7,495	59	4	13	1
Water-cooled chiller - 03																						
90.1-10 Min CCOoling Tower Axial Fan		87	7	16	1	0	0	0	60	386	496	83	0	0	0	0	0	7,735	71	8	10	10

Outputs

ENERGY CONSUMPTION SUMMARY

By Sebesta Inc.

	Elect Cons. (kWh)	Gas Cons. (kBtu)	Water Cons. (1000 gals)	% of Total Building Energy	Total Building Energy (kBtu/yr)	Total Source Energy* (kBtu/yr)
Alternative 1						
Primary heating						
Primary heating		1,149,043		42.5 %	1,149,043	1,209,519
Other Htg Accessories	10,652			1.3 %	36,354	109,073
Heating Subtotal	10,652	1,149,043		43.8 %	1,185,397	1,318,592
Primary cooling						
Cooling Compressor	70,606			8.9 %	240,979	723,009
Tower/Cond Fans	14,770		243	1.9 %	50,412	151,250
Condenser Pump	4,912			0.6 %	16,766	50,303
Other Clg Accessories	4,689			0.6 %	16,005	48,020
Cooling Subtotal...	94,978		243	12.0 %	324,162	972,582
Auxiliary						
Supply Fans	111,798			14.1 %	381,568	1,144,818
Pumps	18,351			2.3 %	62,632	187,914
Stand-alone Base Utilities				0.0 %	0	0
Aux Subtotal....	130,149			16.4 %	444,200	1,332,732
Lighting						
Lighting	120,900			15.3 %	412,633	1,238,023
Receptacle						
Receptacles	99,029			12.5 %	337,984	1,014,054
Communication						

Outputs

MONTHLY UTILITY COSTS

By Sebesta Inc.

Utility	Jan	Feb	Mar	Apr	----- May	Monthly Utility Costs June	July	----- Aug	Sept	Oct	Nov	Dec	Total
Alternative 1													
Electric													
On-Pk Cons. (\$)	3,115	2,822	3,368	3,110	4,666	5,169	5,177	5,111	4,340	3,503	3,091	3,012	46,482
Gas													
On-Pk Cons. (\$)	1,698	1,444	1,641	651	0	0	0	0	3	578	1,248	1,846	9,110
Monthly Total (\$):	4,814	4,265	5,009	3,761	4,666	5,169	5,177	5,111	4,343	4,081	4,339	4,858	55,592
Building Area = 55,056 ft ²													
Utility Cost Per Area = 1.01 \$/ft ²													
Alternative 2 - 0° Rotation													
Electric													
On-Pk Cons. (\$)	2,640	2,384	2,850	2,532	4,020	4,702	5,150	4,614	3,599	2,876	2,589	2,558	40,514
Gas													
On-Pk Cons. (\$)	2,006	1,714	1,787	649	109	90	84	96	110	582	1,047	2,247	10,521
Monthly Total (\$):	4,646	4,098	4,638	3,182	4,129	4,792	5,233	4,710	3,708	3,458	3,636	4,806	51,035
Building Area = 55,056 ft ²													
Utility Cost Per Area = 0.93 \$/ft ²													

Outputs

Alternative 2**ASHRAE Baseline 90.1-10 C**

Yearly Time of Peak: 17(Hr) 7(Month)


Equipment Description	Electrical Demand (kw)	Percent of Total (%)
Cooling Equipment		
Air-cooled unitary - 001	125.59	47.10
Subtotal	125.59	47.10
Heating Equipment		
Boiler - 001	2.13	0.80
Subtotal	2.13	0.80
Fan Equipment		
Sys 5: System - 005	2.05	0.77
Sys 4: System - 004	12.10	4.54
Sys 3: System - 003	14.79	5.55
Sys 2: System - 002	15.33	5.75
Sys 1: System - 001	18.30	6.86
Subtotal	62.57	23.47
Miscellaneous		
Base Utilities	0.00	0.00

Outputs

The (original) Purpose...




Existing Buildings




Existing Buildings Calibrated Outputs


Total Utility Cost



Electrical Utility Cost




Natural Gas Utility Cost



Existing Buildings Calibrated Outputs

Figure 2.3: Average Monthly Usage from May 2008 to June 2011.



Existing Buildings

Calibrated Outputs





Onsite Observations



Energy
Model



Implications:

Quantify savings

Evaluate sizing

Determine deficiency magnitude

Environmental conditions

Understand interactions

GUIDE DECISIONS

Building Deficiency

ACTION	REQUIRED REACTION	Y (✓)	N (✓)	COMMENTS	R (✓)	C (✓)
2. Adjust thermostat set-point to equal current space temperature.	Damper goes to minimum position.	☐	☒	VAV is wide open 1343 cfm (total of outlets)	☐	☐
	Heating valve closed.	☒	☐		☐	☐
	Record CFM.	☒	☐		☐	☐
	CFM is at minimum per TAB set-point.	☐	☒		☐	☐
	Initial discharge temp.	☐	☐	☐	☐	
	Final discharge temp.	☐	☐	☐	☐	
	Final upstream temp.	☒	☐	78°F	☐	☐
Record issues VAV does not go to minimum.				Issue Log Item: _____ Initial _____ Date _____		

Zone Design Flow Rates

Min Design Flow: cfm/ft2

OA Flow/Person: cfm

Minimum Flow Ratio: ratio

Building Deficiency

Table 9. Supply Duct Thermal Gain Results

	AHU-BB (1969)	AHU-BQ (1964)	AHU-BM (1960)	AHU-BD (1949)
Insulated	Yes	Yes	No	No
AHU Discharge temp	60.6	56.4	59.4	62.4
VAV Upstream temp	61.7	-	-	-
VAV Downstream temp	61.9	-	-	-
Diffuser Neck temp	62.4	-	-	66.3
Diffuser Face temp	65.7	59.8	65.8	67.5
Delta T	5.1	3.4	6.4	5.1



Duct Losses

Duct Air Loss: ratio

Air Loss Type:

Duct Air Loss OA: ratio

Duct Zone:

Supply Duct UA: Btu/h-°F


Duct Delta T: °F (delta)

Return Duct UA: Btu/h-°F

Hot Duct UA: Btu/h-°F

Hot Duct DT: °F (delta)

Building Deficiency



As-Found Building Pressurization Diagram



Infiltration Method: **Air Change**

Air Change Method

Air Changes/Hour: 0.00


Infiltration Flow: 0.0103 cfm/ft2

Building Deficiency

Table 4.11

Outside Humidity		ERV control sensors			Other zone sensors	
		ERV-1	ERV-2	ERV-3	C201	B200
Device Reading	32	37.7	37.7	36.5	38.6	36.8
Weather.com	34	(Controls)			57.1	57
Error	1.9	19.4	27.8	12.2	18.5	20.2

Average Sensor Error: 19.6 % RH



Day Schedule Name:

Type:

Hourly Values

Mdnt - 1:	0.0000	ratio	8-9 am:	1.0000	ratio
1-2 am:	0.0000	ratio	9-10 am:	1.0000	ratio
2-3 am:	0.0000	ratio	10-11 am:	1.0000	ratio
3-4 am:	0.0000	ratio	11-noon:	1.0000	ratio
4-5 am:	0.0000	ratio	noon-1:	1.0000	ratio
5-6 am:	0.0000	ratio	1-2 pm:	1.0000	ratio
6-7 am:	0.0000	ratio	2-3 pm:	1.0000	ratio
7-8 am:	0.0000	ratio	3-4 pm:	1.0000	ratio

Building Deficiency

Figure 4.1
Geothermal Loop Return Water Temp





Figure 4.2: Projected Maximum Wellfield Temperatures for 25 Years.





Energy modeling and retrocommissioning (RCx) can effectively share information to aid in building investigations and help guide decisions



Thank you for your time!

QUESTIONS?

This concludes the educational content of this activity

This concludes The American Institute of Architects
Continuing Education Systems Course

John Bixler, PE

NV5, Inc

John.bixler@NV5.com

319.558.9299

